



Specializing in Fire, Building, and Life Safety

Corporate Office
2420 Alft Lane
Elgin, IL 60124
P: 847.697.1300
F: 847.697.1310
www.firesafetyfsci.com

Regional Office
23650 Woodward Avenue
Suite 200
Pleasant Ridge, MI 48069
P: 248.545.3330
F: 248.545.3376

FIRE ALARM SYSTEM SUBMITTALS

Information Required for Submittal to be Reviewed by FSCI

See NFPA 72 for a complete submittal list.

- Plans must be to scale and include a **scope of work** outlining details of the project.
- Plans must show job name and complete address.
- The square foot area of the building must be noted on the plans.
- A summary sheet or symbol list showing a device count shall be provided.
- Catalog cut sheets must be provided and **highlighted** for all components to be installed.
- Specific details must be provided regarding the offsite monitoring of the system including type of transmission means and name and location of receiving station.
- All wiring information must be shown on the plans including size, type, and all point-to-point wire runs.
- Complete battery back up calculations must be provided that clearly note **battery size to be provided**.
- Voltage drop calculations using the "UL MAX" values for notification appliances must be provided.
- All plans must have the contractors name, address, and phone number.