



*Specializing in Fire, Building, and Life Safety*

**Corporate Office**  
2420 Alft Lane  
Elgin, IL 60124  
P: 847.697.1300  
F: 847.697.1310  
[www.firesafetyfsci.com](http://www.firesafetyfsci.com)

---

**Regional Office**  
23650 Woodward Avenue  
Suite 200  
Pleasant Ridge, MI 48069  
P: 248.545.3330  
F: 248.545.3376

## **CLEAN AGENT SYSTEM SUBMITTALS**

### **Information Required for Submittal to be Reviewed by FSCI**

**See NFPA 2001 for a complete submittal list.**

- Plans must be to scale and clearly show all work to be done.
- Plans must show the job name and complete address.
- A key plan shall be provided showing the area of work in the building.
- Complete catalog cut sheets shall be provided for all equipment to be used.
- The scope of work shall include a description of hazard being protected and type/manufacture of agent being used.
- Calculations for required agent quantity and discharge time shall be provided.
- All alarm portions of the system shall comply with the submittal requirements of a fire alarm system.