

Specializing in Fire, Building, and Life Safety

Corporate Office 2420 Alft Lane Elgin, IL 60124 P: 847.697.1300

F: 847.697.1310 Www.firesafetyfsci.com

Regional Office

23650 Woodward Avenue Suite 200 Pleasant Ridge, MI 48069 P: 248.545.3330 F: 248.545.3376

SPRINKLER SYSTEM SUBMITTALS

Information Required for Submittal to be Reviewed by FSCI

See NFPA 13 for a complete submittal list.

Plans must be to scale and clearly show work to be done including a detailed scope of work .
Plans must show the job name and complete address.
The specific type and quantity of sprinklers must be provided on every page.
Catalog cut sheets for all equipment including sprinklers, valves, etc. must be included and highlighted.
Fire hydrant flow test information must be dated and less than 1 year old.
Hydraulic calculations must clearly show the friction loss for the backflow preventer and include a graph curve sheet.
All hydraulic node points must be clearly shown on the drawings .
All ceiling information including soffits, heights, construction type, slope, etc. must be shown and noted with cross section detailed on the plans.
Specific code sections and storage information must be provided for all design densities over an Ordinary Group II.
All plans must have the contractors name, address, and phone number.
Provide a scaled site plan clearly showing the building fire department connection and fire hydrant locations.

1 11/2013