



FIRE SAFETY CONSULTANTS, INC.

FIRE ALARM SYSTEM SUBMITTALS

The following is a list of items that need to be included with your submittal to FSCI for review. Please refer to NFPA 72 for a complete list of required information.

Plans shall be on a standard architectural paper size and drawn or printed to a standard architectural scale (1/8 inch per foot or larger).

Plans shall clearly show the project name and proper street address.

Plans shall clearly show the contact information (name, phone number, email) of the installing contractor and designer.

Plans shall clearly show the required qualification (NICET or PE) of the engineer or designer, if applicable.

Plans shall include column lines, room names, or room numbers so specific areas can be identified.

The plans shall include a complete “Scope of Work” for the project outlining the specific details of the work to be completed. This shall also include specific monitoring agency and transmission equipment to be used.

The plans shall include a complete symbol list (with device count) identifying all parts of the system. This shall include specific wire type (FPL, FPLR, FPLP) and size to be used.

The plans shall include any and all details (ceiling, soffit, elevation) needed to properly convey the location and layout of the equipment.

The submittal shall include complete data sheets for all equipment and material to be used on the project. Data sheets shall be highlighted to the specific model or part number used.

The submittal shall include complete battery and voltage drop calculations as required for the system to be installed. Summary calculations will not be accepted.

If you have any questions regarding the submittal process for a specific municipality, please feel free to contact our office at info@firesafetyfsci.com and we will be happy to help.